

SU ANALİZ RAPORU

Firma BKS MÜH.
Bölge SAMSUN
Drew Temsilcisi UTKU ÇİFTÇİ
Tarih: 10.04.2011

NUMUNE	HAM SU	TERS OZMOS
pH	7,68	7,3
İletkenlik(μ S/cm)	350	10
Toplam Sertlik (CaCO ₃)	100	2
Toplam Alkalite(CaCO ₃)	175	<10
P.Alkalite(CaCO ₃)	0	0
Klorür (Cl)	5	<5
Silis	10,4	1
Sülfat (SO ₃)	13	0,9
Nitrat	1,3	1,3
Toplam Demir (Fe)	0,3	0,01

